



PIPE SIZE	4"	6"	8"	10"	12"	16"	20"	24"	30"
MAXIMUM ALLOWED TRENCH WIDTH	20"	20"	20"	22"	24"	28"	32"	36"	42"

*** NOTE:**

DEPTH OF COVER SHALL BE 36" ON RESIDENTIAL STREETS.
 DEPTH OF COVER SHALL BE 42" ON ARTERIAL STREETS.

WATER STANDARD



DRAWN: NGUYEN BUI
DATE: 04-05-2001
SCALE: AS SHOWN

TYPICAL TRENCH DETAIL

APPROVED: *Chet F. Arden* 4 0 3 3 0 05/09-06
 ASSISTANT DIRECTOR - WATER OPERATIONS RCE NO. DATE

DWG. NO.
W - 6

SHEET
1 OF 1